

Annexure - C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 781

Dated : 28/04/26

It is certified that an inspection team headed by Shashi Kant Kumar

Chemist. (Name of Officers with designation)

from CHEMIST P.H. DIVISION SHBIKHPURA PHED

inspected the **Divine Light Public School, West to Gramin Bank / Sahara India, Barbigha,**

Sheikhpura, Bihar - 811101 (Name & Address of the school) on 02/04/26

(date of inspection) and on the basis of Water Test Report (Attached) bearing no. SHPLW/252/R/02

dated 08.04.2026 of DLWTL P.H. DIVISION (PHED Lab) certified that the

SHBIKHPURA
Divine Light Public School (Name of school) has safe drinking water facilities for the students

and members of staff of the institution. School is also maintains the hygienic sanitation condition

in the school building & the campus as per norms prescribed by the Central / State / U.T. Govt.

This certificate is valid till SIX MONTHS.

Signature with Seal : Ranjit Kumar Singh

Name

Ranjit Kumar Singh

Designation

Executive Engineer

Name & Address of the Office / Department :

PHED
28/04/26

To,

DIVINE LIGHT PUBLIC SCHOOL

West to Gramin Bank / Sahara India,

Barbigha, Sheikhpura (Bihar) – 811101

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized office / PHED Lab / local bodies

CHAIRPERSON
Kiran Singh
DIVINE LIGHT PUBLIC SCHOOL
BARBIGHA (SHEIKHPURA)

PRINCIPAL
DIVINE LIGHT PUBLIC SCHOOL, BARBIGHA
CBSE Affiliation No.: 330546



Government of Bihar.
Public Health Engineering Department
District Level Water Testing Laboratory
Sheikhpura, Near Jakhraj Asthan,
Dist-Sheikhpura, Bihar Pin-811105
Email: shashikant88kumar@gmail.com. Mob:- 9006336473



DOC No: SHP\SAMP\05\00

TEST REPORT

Name & Address Of the Customer Rajesh Kumar Block-Barbigha Panchayat-Barbigha Village-Barbigha Divine Light Public School	URL NO-	TC154332500000002F
	Report No.	: SHP/W/26-27/R/02
	Date	: 02.04.2026
	Sample No.	: SHP/W/26-27/02
	Sample Description	: Drinking Water
	Sample Mark/ Location	: Divine Light Public School
	Sample Collected On	: 02.04.2026
	Sampling Plan & Method	: IS 17614 Part-1 2021
	Sample Submitted On	: 02.04.2026
	Date of Performance (s)	: 02.04.2026 to 08.04.2026
	Ref No. Date	:

Analysis Result

SL No.	Test Parameter	Test Method	IS 10500:2012Amd. 1 & 2		Result
			Acceptable Limit	Permissible Limit	
1	pH Value in 25°C	IS 3025(Part 11) : 2022	6.5-8.5	No Relaxation	7.4
2	Turbidity in NTU	IS 3025 (Part 10) :2024	1	5	1.0
3	TDS in mg/l	IS 3025(Part 16) : 2023	500	2000	116.6
4	Total Hardness in mg/l	IS 3025(Part 21) : 2019	200	600	78.40
5	Calcium in mg/l	IS 3025(Part 40) : 2024	75	200	16.68
6	Magnesium in mg/l	APHA 24th Edition -3500- Mg B; 2023	30	100	8.56
7	Iron in mg/l	APHA 24th Edition -3500-Fe Method B (Phenanthroline Method) : 2023	1	No Relaxation	0.12
8	Chloride in mg/l	IS 3025(Part 32) : 2025	250	1000	9.78
9	Total Alkalinity in mg/l	IS 3025(Part 23) : 2023	200	600	44.44
10	Colour in HU	IS 3025 (Part 4) : 2021	5	15	<1
11	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable
12	Taste	IS 3025 (Part 8) : 2023	Agreeable	Agreeable	Agreeable
13	Fluoride mg/l	APHA 24th Edition -4500F C; 2023	1	1.5	0.69

For District Level Water Testing Laboratory, Sheikhpura
Reviewed By



End of Report

- The results relate only to the items(s) tested.
- This Test Report shall not reproduced without the permission of District Level Water Testing Laboratory, Sheikhpura
- The reserved part of sample(s), except perishable sample(s), shall be retained for 15 day's from the date of issue of the Test report.

CHAIRPERSON
Kiran Singh
DIVINE LIGHT PUBLIC SCHOOL
BARBIGHA (SHEIKHPURA)

PRINCIPAL
DIVINE LIGHT PUBLIC SCHOOL, BARBIGHA
CBSE Affiliation No.:330546

PROFORMA FOR SANITARY CONDITION CERTIFICATE

No. 1444

Dated. 12/8/26

It is certified that an inspection team headed by RAJ BARDHAN (APSWMO).

Sanitation and Waste Management Officer, From Nagar Parishad, Barbigha inspected the

Divine Light Public School, West to Gramin Bank / Sahara India, Barbigha, Sheikhpura,

Bihar - 811101 on 10/08/2026 (date of inspection) certified that the Divine

Light Public School maintains the hygienic sanitation condition in the school building & the

campus as per norms prescribed by the Central / State / U.T. Govt.

This certificate is valid till March, 2027.

Signature with Seal : A. N.

Name

Designation

Raj Bardhan

APSWMO.

Name & Address of the Office / Department

Nagar Parishad Barbigha (UDMD).

To,

DIVINE LIGHT PUBLIC SCHOOL

West to Gramin Bank / Sahara India,

Barbigha, Sheikhpura (Bihar) – 811101

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized office / local bodies.

CHAIRPERSON
Kiran Singh
DIVINE LIGHT PUBLIC SCHOOL
BARBIGHA (SHEIKHPURA)

PRINCIPAL
DIVINE LIGHT PUBLIC SCHOOL, BARBIGHA
CBSE Affiliation No.: 330546